



TOWN OF PERINTON

1350 TURK HILL ROAD, FAIRPORT, NEW YORK 14450-8796

(585) 223-0770, Fax: (585) 223-3629, www.perinton.org

BUILDING PERMIT REQUIREMENTS FOR AUTOMATIC STANDBY GENERATORS

1. Contact RG&E to determine if your gas service pressure needs to be elevated.
2. Submit two copies of your survey map indicating the proposed location for the generator. It must be a minimum of 5 feet from the house and cannot be located under a deck or any other structure. The exhaust must be 5 feet from any door or window.

It is recommended the generator be located in the rear yard.

3. The contractor must have **General Liability, Workers' Compensation and Disability Benefits** insurance on file with the Town of Perinton before a permit can be issued. Please call the Code Enforcement and Development Department with any questions.
4. Submit two copies of a gas piping layout for the entire gas distribution system of the building. Indicate all pipe lengths, pipe size, type, the quantity of 90 degree bends in each section and BTU rating of the appliance. Indicate the gas pressure, standard at 6 inch water column or elevated at 11 inch water column.

The generator **is recommended** to be fed by a separate pipe from the gas meter manifold. To determine the size of pipe required, the length of pipe must be increased 5 feet for every 90degree bend in the run.

Gas piping located outside of the building must protected from corrosion, i.e. **paint**.

The use of 90 degree street ells is prohibited.

5. Submit two copies of the installation and specification pages from the owners manual and include the following information:

Make	Model	Wattage	Full Load BTU Rating	Operating Pressure

6. After the building department has reviewed this information and received approval from RG&E a permit can be issued.
7. After installation of the generator, an electrical inspection and final Certificate of Compliance inspection must be scheduled with the Code Enforcement and Development.
8. It is recommended that you have RG&E inspect the gas line for any leaks.
9. See the current Town of Perinton fee schedule at www.perinton.org or visit the Code Enforcement and Development office in the Town Hall.

Natural Gas Appliance Inventory for Residential Property

Name _____

Address _____

Town _____ Zip _____

Phone # _____

List all natural gas appliances and the input British thermal units (Btu) rating of each.

Appliance Type	Number of each appliance	BTU/hr rating of each appliance	Total Btu/hr
_____	_____	_____	_____
Furnace	_____	_____	_____
Water Heater	_____	_____	_____
Boiler	_____	_____	_____
Room/Space Heater	_____	_____	_____
Fireplace, Fireplace insert or Free-Standing Heating Stove	_____	_____	_____
Range/Cooktop	_____	_____	_____
Clothes dryer	_____	_____	_____
Pool/Spa Heater	_____	_____	_____
Gaslights	_____	_____	_____
Garage/Patio Heater	_____	_____	_____
Generator at Full Load	_____	_____	_____
Outdoor Grill (not propane)	_____	_____	_____
		Total Connected Btu/hr	_____

If the total connected load is 350,000 Btu or greater, a meter upgrade is required, contact RG&E.